

CONSUMER CONFIDENCE REPORT 2023 CITY OF ROCKWOOD



Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The Rockwood Water Department and the Great Lakes Water Authority vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum level or any other water quality standard.

Where does my water come from?

Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

GLWA has initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. GLWA participates in a National Pollutant Discharge Elimination System permit discharge program and has an emergency response management plan. In 2015, GLWA received a grant from The Michigan Department of Environmental Quality to develop a source water protection program for the Detroit River intakes. The program includes seven elements that include the following: roles and duties of government units and water supply agencies, delineation of a source water protection area, identification of potential of source water protection area, management approaches for protection, contingency plans, siting of new sources and public participation and education.

If you would like to know more about the Source Water Assessment report or a complete copy of this report please contact the water department at (734) 379-9496

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800 426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Lead Contamination in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Rockwood is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800 426-4791).

Cryptosporidium Language

The Great Lakes Water Authority monitored for Cryptosporidium in our source water (Detroit River) from our Southwest Water Treatment Plant during 2016. Cryptosporidium was detected twice in our source water samples. A follow-up water sample was collected from the treated water and Cryptosporidium was not found to be present. Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most commonly-

used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immunocompromised people, infants and small children and the elderly are at greater risk of developing life threatening illness. We encourage immune-compromised individuals to consult their doctors regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

If you have any questions or comments contact: Robert Boron
Director of Public Services
32409 Fort Road
Rockwood, MI 48173
(734) 379-9496

2023 Southwest Regulated Detected Contaminants Table

2023 Inorganic Chemicals - Annual Monitoring at Plant Finished Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation	Major Sources in Drinking Water
Fluoride	04-11-2023	ppm	4	4	0.46	n/a	no	Erosion of natural deposit; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	04-11-2023	ppm	10	10	0.63	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Lead and Copper Monitoring at the Customer's Tap in 2023								
Regulated Contaminant	Unit	Year Sampled	Health Goal MCLG	Action Level AL	90 th Percentile Value*	Range of Individual Samples Results	Number of Samples Over AL	Major Sources in Drinking Water
Lead	ppb	2023	0	15	0 ppb	0ppb-2ppb	LEAD	Lead services lines, corrosion of household plumbing including fittings and fixtures; erosion of natural deposits.
Copper	ppm	2023	1.3	1.3	0 ppm	0ppm-2ppm	COPPER	Corrosion of household plumbing systems; Erosion of natural deposits.

* The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

2023 Disinfection Residual - Monitoring in the Distribution System								
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest Level RAA	Range of Quarterly Results	Violation	Major Sources in Drinking Water
Total Chlorine Residual	2023	ppm	4	4	0.69	0.55-0.77	no	Water additive used to control microbes

2023 Disinfection By-Products - Stage 2 Disinfection By-Products Monitoring in the Distribution System								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level LRAA	Range of Quarterly Results	Violation	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2023	ppb	n/a	80	38	26 - 59	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2023	ppb	n/a	60	12	9 - 18	no	By-product of drinking water chlorination

2023 Turbidity - Monitored Every 4 Hours at the Plant Finished Water Tap			
Highest Single Measurement Cannot Exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation	Major Sources in Drinking Water
0.09 NTU	100%	no	Soil Runoff
Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system			

Regulated Contaminant	Treatment Technique	Typical Source of Contaminant
Total Organic Carbon ppm	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC is measured each quarter and because the level is low, there is no requirement for TOC removal.	Erosion of natural deposits

2023 Special Monitoring						
Contaminant	Test Date	Unit	MCLG	MCL	Highest Level Detected	Source of Contaminant
Sodium	04-11-2023	ppm	n/a	n/a	6.3	Erosion of natural deposits

These tables are based on tests conducted by GLWA in the year 2023 or the most recent testing done within the last five calendar years. GLWA conducts tests throughout the year only tests that show the presence of a substance or require special monitoring are presented in these tables. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. The data is representative of the water quality, but some are more than one year old.

Example UCMR table IF NEEDED

About Unregulated Contaminant Monitoring

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where these contaminants occur and whether it needs to regulate those contaminants.

2019 Unregulated Contaminants - Monitored at the Plant Finished Tap							
Unregulated Contaminant	Test Date	Unit	Highest Level of Detection	SMCL	Range of Detection	Noticeable Effects Above the SMCL	Source of Contaminant
Manganese	2019	ppb	0.48	50	0.0-0.48	black to brown color; black staining; bitter metallic taste	Erosion of natural deposits and corrosion of iron pipes

YEAR Unregulated Contaminants				
Unregulated Contaminant	Average Level Detected	Range	Year Sampled	Comments
[Name of Unregulated Contaminant] (unit)				
[Name of Unregulated Contaminant] (unit)				

2023 Southwest Tap Water Mineral Analysis

Parameter	Units	Max.	Min.	Avg.	Parameter	Units	Max.	Min.	Avg.
Turbidity	NTU	1.80	0.01	0.22	Phosphorus	ppm	0.73	0.41	0.52
Total Solids	ppm	174	120	139	Free Carbon Dioxide	ppm	13.9	6.0	9.5
Total Dissolved Solids	ppm	165	97	127	Total Hardness	ppm	166	103	120
Aluminum	ppm	0.084	0.021	0.045	Total Alkalinity	ppm	94	70	80
Iron	ppm	0.5	0.2	0.3	Carbonate Alkalinity	ppm	0	0	0
Copper	ppm	0.001	ND	0.001	Bi-Carbonate Alkalinity	ppm	94	70	80
Magnesium	ppm	8.8	7.4	7.9	Non-Carbonate Hardness	ppm	72	19	41
Calcium	ppm	33.3	25.2	27.4	Chemical Oxygen Demand	ppm	11.7	2.0	4.4
Sodium	ppm	9.4	4.7	5.6	Dissolved Oxygen	ppm	14.9	8.0	10.5
Potassium	ppm	1.3	0.9	1.1	Nitrite Nitrogen	ppm	ND	ND	0.0
Manganese	ppm	0.002	ND	0.000	Nitrate Nitrogen	ppm	1.47	0.29	0.50
Lead	ppm	ND	ND	0.000	Fluoride	ppm	0.84	0.10	0.62
Zinc	ppm	0.002	ND	0.000	pH		7.37	7.05	7.23
Silica	ppm	2.7	1.3	2.0	Specific Conductance @ 25 °C	µmhos	297	182	213
Sulfate	ppm	36.0	23.4	26.3	Temperature	°C	23.2	2.3	12.6
Chloride	ppm	14.5	7.5	10.3					

Key to the Detected Contaminants Table

Symbol	Abbreviation	Definition/Explanation
AL	Action Level	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
°C	Celsius	A scale of temperature in which water freezes at 0° and boils at 100° under standard conditions.
>	Greater than	
HAA5	Haloacetic Acids	HAA5 is the total of bromoacetic, chloroacetic, di-bromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
Level 1	Level 1 Assessment	A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our system.
LRAA	Locational Running Annual Average	The average of analytical results for samples at a particular monitoring location during the previous four quarters.
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow a margin of safety.
MRDL	Maximum Residual Disinfectant Level	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
n/a	not applicable	
ND	Not Detected	
NTU	Nephelometric Turbidity Units	Measures the cloudiness of water.
pCi/L	Picocuries Per Liter	A measure of radioactivity
ppb	Parts Per Billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
ppm	Parts Per Million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
RAA	Running Annual Average	The average of all analytical results for all samples during the previous four quarters.
SMCL	Secondary Maximum Contaminant Level	
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
TTHM	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.
µmhos	Micromhos	Measure of electrical conductance of water

Communities served by Southwest water treatment plant.
Required information on Great Lakes Water Authority's (GLWA) Administrative Compliance Agreement (ACA) with Michigan Department of Environment, Great Lakes, and Energy Drinking Water and Environment Health Division (EGLE):

Great Lakes Water Authority (GLWA) is required to notify water users of any unresolved significant deficiencies identified by the Michigan Department of Environment, Great Lakes, and Energy, Drinking Water and Environment Health Division (EGLE). Below is the status of significant deficiencies in the GLWA water system identified by EGLE:

Date Identified by EGLE	Description	Compliance Agreement Deadline	Status
08-02-2022	Improper rapid mixing and coagulant feed location at the Southwest water plant	12-31-2027	Contractor has been identified
08-02-2022	Inoperable flocculation equipment at the Southwest water plant	07-31-2031	Preliminary procurement phase